



Major Event Report

Date of Major Event: September 12, 2021

Prior to the Major Event

1. Did the distributor have any prior warning that the Major Event would occur?

Yes

Additional Comments

Environment Canada issued a severe thunderstorm warning for Southwestern Ontario.

2. If the distributor did have prior warning, did the distributor arrange to have extra employees on duty or on standby prior to the Major Event beginning?

Yes

Brief description of arrangements, or explain why extra employees were not arranged.

London Hydro did have extra London Hydro employees on duty during the storm. London Hydro did bring in additional contractors to assist in restoration activities during the storm.

3. If the distributor did have prior warning, did the distributor issue any media announcements to the public warning of possible outages resulting from the pending Major Event?

No

4. Did the distributor train its staff on the response plans to prepare for this type of Major Event?

Yes

During the Major Event

1. Please identify the main contributing cause of the Major Event as per the table in section 2.1.4.2.5 of the Electricity Reporting and Record Keeping Requirements.

Adverse Weather – Wind

Please provide a brief description of the event (i.e. what happened?). If selected “Other”, please explain.

Severe thunderstorms, accompanied by high winds and lightning, passed through London Hydro's distribution area on September 12, 2021 at around 10pm. The resulting high wind from the storm knocked down several trees throughout the region that damaged various hydro poles and power lines.

2. Was the IEEE Standard 1366* used to derive the threshold for the Major Event?

*The OEB preferred option

Yes, used IEEE Standard 1366

3. When did the Major Event begin?

Date: September 12, 2021

Time (for example HH:MM AM): 10:11 PM

4. Did the distributor issue any information about this Major Event, such as estimated times of restoration, to the public during the Major Event?

Yes

If yes, please provide a brief description of the information. If no, please explain.

London Hydro issued estimated times of restoration (ETR) for the various outage events through Twitter, IVR, Email, and Text. London Hydro also issued ETR through the outage map on our website, which gets updated every minute with the most updated information.

5. How many customers were interrupted during the Major Event?

8,004 customers

What percentage of the distributor's total customer base did the interrupted customers represent?

4.90%

6. How many hours did it take to restore 90% of the customers who were interrupted?

6 hours

Additional Comments

The major event started at 10:11pm on September 12th, and over 90% of customers were restored by 3:52am on September 13th.

7. Were there any outages associated with Loss of Supply during the Major Event?

No

If so, please report on the duration and frequency of Loss of Supply outages.

N/A

8. In responding to the Major Event, did the distributor utilize assistance through a third party mutual assistance agreement with other utilities?

No

9. Did the distributor run out of any needed equipment or materials during the Major Event?

No

If so, please describe the shortages.

N/A

After the Major Event

1. What steps, if any, are being taken to be prepared for or mitigate such Major Events in the future (i.e., staff training, process improvements, system upgrades)?

Others

Additional Comments:

London Hydro will be looking to complete a risk analysis based on field inspections of trees that have adequate clearances from the lines, but could have severe impacts to reliability if the entire tree or large portions of it were to come down.